

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. २२२

Dated: ०१/१०/२६

It is certified that an inspection team headed by Shri Narsingh Farindra
(Name of Officers with designation) from EE (Water Works) PHED RMC

inspected the Shri Gujrati English Medium Hr.Sec.School, Sec-4, Devendra Nagar, Raipur(C.G)

(Name & Address of the school) on 11-9-26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 321 (A)

dated 11-9-26 of Nagar Nigam Filter Plant Lab (PHED Lab) certified that the Shri

Gujrati English Medium Hr.Sec.School, (Name of school) has safe drinking water facilities

for the students and members of staff of the institution. School is also maintains the hygienic

sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 Yrs.

Signature with Seal : जोन आयुक्त

Name : जोन प्र-०२

Designation : नगर प्रबन्धन निगम,

Name & Address of the Office / Department : रायपुर (छ.ग.)

To,

Shri Gujrati English Medium Hr.Sec.School,

Sec-4, Devendra Nagar, Raipur(C.G)

(Name & Address of the Institution)



Report No. 321(A)
Date - 11/09/2026

MUNICIPAL CORPORATION RAIPUR
WATER ANALYSIS LABORATORY RAIPUR (C.G.)
WATER ANALYSIS REPORT

Sample Sent By : Shri Gujrati English Medium Hr. Sec. School, Devendra Nagar, Raipur (C.G.).

Particulates : (1) Sample Collected From :- By Party (Filter Water).
(2) Date of Collection :- 08/09/2026
(3) Date of Delivery to Laboratory :- 08/09/2026
(4) Date of Analysis :- 08/09/2026 to 10/09/2026


	Parameters	Unit	Acceptable limit As per CPHEEO Manual and IS:10500	Cause For Rejection	Result
(A)	Physical Exam.				
	Turbidity	N.T.U.	1	05	0.5
	Colour	T.C.U.	5	15	Nil
	Taste & Odour	-	Unobjectionable	Objectionable	Unobjectionable
(B)	Chemical Exam.				
	pH Value	Scale	6.5 to 8.5	<6.5 or >8.5	7.1
	Total Alkalinity	mg/L	200	600	52
	Total Acidity	mg/L	-	-	-
	Total Dissolved solids	mg/L	500	2000	88
	Total Hardness as CaCO ₃	mg/L	200	600	48
	Calcium (Ca)	mg/L	75	200	9.60
	Magnesium (Mg)	mg/L	≤30	150	5.76
	Iron as (Fe)	mg/L	0.1	1.0	Nil
	Manganese (Mn)	mg/L	0.05	0.5	Nil
	Chloride (Cl)	mg/L	200	1000	12
	Sulphate (SO ₄)	mg/L	200	400	10.56
	Flourides (F)	mg/L	1.0	1.5	Nil
	Nitrate (NO ₃)	mg/L	45	45	1.0

(C) **Bacteriological Exam (MPN Test) :-** **MPN** **Result**

Acceptable Value - 0 to 3

Cause For Rejection - Above 3

0


Executive Engineer
Filter Plant
Municipal Corporation
Raipur (C G)


CHEMIST
FILTER PLANT
MUNICIPAL CORPORATION
RAIPUR